

DATE

27/01/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI GUIDONIA

PRODUCT

Rotore ANSALDO CTF630K
N°Comm 2023-0045

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.01265	15.13	PASS	7.7	3.1	PASS
Phase 2			0.01298		PASS			
Phase 3			0.01305		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	525	6.4	2.279 m	0.7	6.4	82.14	0	GO	99.3
Phase 2	525		2.291 m			82.14		GO	
Phase 3	514		2.296 m			82.14		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1055	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1054	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

