

DATE

08/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI GUIDONIA

PRODUCT

ROTORE SAVIGLIANO AT8000_L6
N°60518 Comm 2023-1046

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00505	14.6	PASS	7.7	1	PASS
Phase 2			0.005		PASS			
Phase 3			0.005		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	828	5.2	1.439 m	0.2	6	68.42	0	GO	99.8
Phase 2	828		1.441 m			68.42		GO	
Phase 3	828		1.439 m			68.42		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1327	0.024	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1328	66.26	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

