

DATE

08/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI GUIDONIA

PRODUCT

statore SAVIGLIANO AT 8000L 6
N°60518 N Comm 2023-1046 (Dopo

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.11093	15.09	PASS	7.7	0.1	PASS
Phase 2			0.1109		PASS			
Phase 3			0.11084		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4178	5.2	25.96 m	1.5	6	54.9	1.9	GO	96.6
Phase 2	4232		26.36 m			54.9		GO	
Phase 3	4232		26.01 m			53.85		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5031	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5031	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

