

DATE

05/10/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI SETTIMELLO

PRODUCT

STATORE SAVIGNANO A6300L6
N_58630 Ncomm 2023_0779

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.27467	18.37	PASS	7.7	1.3	PASS
Phase 2			0.27821		PASS			
Phase 3			0.27507		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4142	5.2	33.57 m	0.3	5	63.64	0	GO	99.7
Phase 2	4214		33.59 m			63.64		GO	
Phase 3	4214		33.66 m			63.64		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4664	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4663	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

