

DATE

30/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI SINISCOLA

PRODUCT

COMELMAR VEM M1001
AKZ355LA6 N Comm 20220242 N

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00665	14.64	PASS	7.7	1.9	PASS
Phase 2			0.00661		PASS			
Phase 3			0.00652		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1092	5.2	317.3 u	0.7	5	28.57	0	GO	99.3
Phase 2	1092		315.1 u			28.57		GO	
Phase 3	1092		316.2 u			28.57		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1106	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

