

DATE

03/08/2023

PRODUCER

R.E.M. SRL

CUSTOMER

ROCOTECH

PRODUCT

ICMET63B4 N°274991 N°Comm
2023-0609

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	43.304	OFF	PASS	7.7	0	PASS
Phase 2			43.304		PASS			
Phase 3			43.304		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	964	5.2	101.3 m	0.9	5	42.11	0	GO	99.1
Phase 2	964		101.2 m			42.11		GO	
Phase 3	964		100.4 m			42.11		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	900.8	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	889	479.2	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	803	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

