

DATE

03/08/2023

PRODUCER

R.E.M. SRL

CUSTOMER

ECOENERGIA CALAGGIO

PRODUCT

COLLETTORE 2Mw V80 N°0126
CORTO ANELLI M-K A 70°C

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1144	0	2	GO

MEGAOHMMETER TEST



	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1144	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1071	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)



venerdì 4 agosto 2023 - 12:28:44