

DATE

31/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

CUMA

PRODUCT

ANSALDO CT355W4 N°Comm 2023-0178

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	3.73854	15.22	PASS	7.7	0.1	PASS
Phase 2			3.73787		PASS			
Phase 3			3.73389		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3857	5.2	228.0 m	0.1	5	82.46	0	GO	99.9
Phase 2	3803		227.8 m			82.46		GO	
Phase 3	3857		228.0 m			82.46		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4028	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4028	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

