

DATE

10/05/2023

PRODUCER

R.E.M. SRL

CUSTOMER

DIANO CEMENTI

PRODUCT

PELLIZZARI GAS 1000_6 N COMM
20223 0121 N REM 10910

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00432	18.02	PASS	7.7	0.3	PASS
Phase 2			0.00432		PASS			
Phase 3			0.00433		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	857	5.2	204.7 u	1.7	5	27.66	0	GO	98.3
Phase 2	871		202.1 u			27.66		GO	
Phase 3	871		201.2 u			27.66		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1041	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	500	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

