

DATE

15/06/2023

PRODUCER

R.E.M. SRL

CUSTOMER

HYROSLIM

PRODUCT

MOT.MARELLI 280S4/8 KW.51/31
VOLTS 380

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.16931	23.17	PASS	7.7	0.1	PASS
Phase 2			0.16934		PASS			
Phase 3			0.16915		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	900	5.2	3.136 m	0.5	5	52.94	0	GO	99.5
Phase 2	900		3.153 m			52.94		GO	
Phase 3	921		3.149 m			52.94		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1118	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

