

DATE

12/02/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO ALLUMINIUM SLIM

PRODUCT

Ventilatore ABB M2AA225SMC 2 n
comm 2023 1053 n rem 16400

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.07721	14.82	PASS	7.7	0.3	PASS
Phase 2			0.07723		PASS			
Phase 3			0.07703		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	5.2	2.865 m	1.2	6	53.85	0	GO	98.8
Phase 2	1478		2.859 m			53.85		GO	
Phase 3	1478		2.830 m			53.85		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

