

DATE

20/06/2023

PRODUCER

R.E.M. SRL

CUSTOMER

ITALCEMENTI

PRODUCT

ANSALDO N3 RXS 710 L 66H
N°044b28001 N_Comm 2023 0491

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.05909	23.53	PASS	7.7	4.4	PASS
Phase 2			0.05871		PASS			
Phase 3			0.05659		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3160	5.2	67.63 m	0.1	5	120	0	GO	99.9
Phase 2	3107		67.71 m			120		GO	
Phase 3	3160		67.70 m			120		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5437	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5438	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

