

## DATE

14/06/2023

## PRODUCER

R.E.M. SRL

## CUSTOMER

ITALCEMENTI

## PRODUCT

ROTORE Motore Ansaldo N3 RXS  
710 L 66H N°044B28001 N Comm

## RESISTANCE TEST

|         | R min | R max | R       | Temperature | Result | max dR % | dR % | Result dR |
|---------|-------|-------|---------|-------------|--------|----------|------|-----------|
| Phase 1 | 0     | 99999 | 0.00668 | 23.71       | PASS   | 7.7      | 1.8  | PASS      |
| Phase 2 |       |       | 0.0068  |             | PASS   |          |      |           |
| Phase 3 |       |       | 0.00669 |             | PASS   |          |      |           |

## SURGE TEST

|         | V   | Toll% L | L       | dL % | Toll% Q | Q     | dQ % | Result | T Q F % |
|---------|-----|---------|---------|------|---------|-------|------|--------|---------|
| Phase 1 | 514 | 5.2     | 2.076 m | 0.3  | 5       | 84.62 | 0    | GO     | 99.7    |
| Phase 2 | 492 |         | 2.082 m |      |         | 84.62 |      | GO     |         |
| Phase 3 | 492 |         | 2.079 m |      |         | 84.62 |      | GO     |         |
| Sample  | 0   |         | 0       |      |         | 0     |      |        |         |

## H. V. TEST

|  | V (V) | I Max (A) | I Meas(A) | Result |
|--|-------|-----------|-----------|--------|
|  | 1039  | 0.009     | 2         | GO     |

## MEGAOHMMETER TEST

|  | V (V) | R Min [MOhm] | R Meas [MOhm] | Result |
|--|-------|--------------|---------------|--------|
|  | 1039  | 101.8        | 5             | GO     |

## SURGE 1.2/50 TEST

|  | V PK (V) | V 50u | Result |
|--|----------|-------|--------|
|  |          |       | N.E.   |

## POLARIZATION INDEX TEST

|  | V PK (V) | Ri | Rf | K | Time (s) |
|--|----------|----|----|---|----------|
|  |          |    |    |   |          |

