

DATE

31/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

ITALCEMENTI

PRODUCT

Tibb QUy 500 kb 4 n_M820012 3 N_
Comm 2023 1004

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.8118	14.95	PASS	7.7	0	PASS
Phase 2			0.8118		PASS			
Phase 3			0.8118		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4607	5.2	149.3 m	4.1	6	63.33	3.3	GO	92.6
Phase 2	4607		155.7 m			61.67		GO	
Phase 3	4607		150.9 m			63.79		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5031	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5044	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

