

DATE

14/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

ITALPOMPE

PRODUCT

MOTORE MARELLI MAA 9496RM N
COM 2023 0078 N REM 15955

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.03931	15.44	PASS	7.7	0.1	PASS
Phase 2			0.03935		PASS			
Phase 3			0.03931		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	2.4	1.321 m	0.2	5	48.84	0	GO	99.8
Phase 2	1328		1.321 m			48.84		GO	
Phase 3	1328		1.319 m			48.84		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1067	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

