

DATE

17/02/2023

PRODUCER

R.E.M. SRL

CUSTOMER

LASIM S.p.A

PRODUCT

MOTORE FIMET MP250M4
N.4P4010 N COMM 20230139 N

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.09405	15.8	PASS	7.7	0.1	PASS
Phase 2			0.09394		PASS			
Phase 3			0.09402		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1371	6.4	1.647 m	0.9	6.4	50	1.9	GO	97.2
Phase 2	1371		1.633 m			50.98		GO	
Phase 3	1371		1.637 m			50.98		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1104	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

