

DATE

29/06/2023

PRODUCER

R.E.M. SRL

CUSTOMER

LASIM

PRODUCT

FIMET MP250M4 N_Comm 2023
0159 (Fine lavoro)

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.10872	24.11	PASS	7.7	0.9	PASS
Phase 2			0.10776		PASS			
Phase 3			0.10774		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1285	5.2	2.136 m	0.8	5	48.94	0	GO	99.2
Phase 2	1285		2.145 m			48.94		GO	
Phase 3	1285		2.128 m			48.94		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1104	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	811.7	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

