

DATE

03/07/2023

PRODUCER

R.E.M. SRL

CUSTOMER

PROMA

PRODUCT

SEIPEE GM355L 4 N_S0123162
Comm 2023 0483

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0073	26.02	PASS	7.7	0.7	PASS
Phase 2			0.00726		PASS			
Phase 3			0.00725		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1071	5.2	515.8 u	0	5	36.84	0	GO	100
Phase 2	1071		515.8 u			36.84		GO	
Phase 3	1071		515.8 u			36.84		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1106	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	642	375	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

