

DATE

16/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT

SEIPEE GM225M6 N_S062112961
Comm 2023 0203

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.21233	14.82	PASS	7.7	0.9	PASS
Phase 2			0.21353		PASS			
Phase 3			0.21433		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1414	2.4	4.353 m	0.9	5	60.38	0	GO	99.1
Phase 2	1371		4.357 m			60.38		GO	
Phase 3	1414		4.393 m			60.38		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

