

DATE

21/11/2023

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA POWER

PRODUCT

MARELLI A6C225M2V1 N°COMM
2023 0936 N°REM 16341

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.10744	16.02	PASS	7.7	0.6	PASS
Phase 2			0.10744		PASS			
Phase 3			0.10685		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1571	5.2	9.050 m	0.2	5	68.57	0	GO	99.8
Phase 2	1571		9.033 m			68.57		GO	
Phase 3	1571		9.045 m			68.57		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1803	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1817	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1071	642	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

