

DATE

04/12/2023

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

ROTORE ECCITATRICE N_Comm
2023 0955

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.19336	14.33	PASS	7.7	0.5	PASS
Phase 2			0.19416		PASS			
Phase 3			0.19436		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1157	5.2	1.383 m	0.3	5	38.46	0	GO	99.7
Phase 2	1157		1.383 m			38.46		GO	
Phase 3	1157		1.378 m			38.46		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

