

DATE

11/09/2023

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

ROTORE ALTERNATORE N°Comm
2023-0356

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Monophasic	0	99999	0.63925	21.57	PASS		0	

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	278.1	0.004	2	GO

MEGAOHMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	279.5	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	267	107	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

