

DATE

26/05/2023

PRODUCER

R.E.M. SRL

CUSTOMER

TELELETTRA

PRODUCT

MARELLI B3C160L2 N COMM 2023
0430

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.699	23.53	PASS	7.7	0.3	PASS
Phase 2			0.69804		PASS			
Phase 3			0.69707		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1446	5.2	7.252 m	0	5	70.83	0	GO	100
Phase 2	1446		7.252 m			70.83		GO	
Phase 3	1446		7.252 m			70.83		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1004	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1000	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

