

DATE

24/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

A R I A

PRODUCT

SIEMENS 1CV3316A
1LE55033AA634AB1_Z N_COMM

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00846	22.82	PASS	7.7	1.5	PASS
Phase 2			0.00853		PASS			
Phase 3			0.00841		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1171	3.8	578.9 u	2	5	38.33	0	GO	98
Phase 2	1157		590.5 u			38.33		GO	
Phase 3	1157		580.3 u			38.33		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1015	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1017	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	707	407	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

