

DATE

22/08/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO GROUP AVEZZANO

PRODUCT

NUM COMM 2024 0647 PROVE
STATORE

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.03316	24.33	PASS	7.7	0.7	PASS
Phase 2			0.03291		PASS			
Phase 3			0.03306		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1321	3.8	1.151 m	1.4	5	42.31	0	GO	98.6
Phase 2	1321		1.149 m			42.31		GO	
Phase 3	1357		1.135 m			42.31		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

