

DATE

01/07/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO GROUP AVEZZANO

PRODUCT

Rotore MENZEL MEBSSF560-04-
087 N°Comm 2024-0537

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01386	27.53	PASS	7.7	4.2	PASS
Phase 2			0.01441		PASS			
Phase 3			0.01445		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1085	3.8	1.358 m	0.5	5	58.93	0	GO	99.5
Phase 2	1085		1.365 m			58.93		GO	
Phase 3	1085		1.363 m			58.93		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1131	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1131	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	642	342	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

