

DATE	PRODUCER	CUSTOMER	PRODUCT
18/07/2024	R.E.M. SRL	BURGO AVEZZANO	STATORE BBC SD560U4 N_144782 N_COMM 2024_0577

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.31786	27.57	PASS	7.7	0.1	PASS
Phase 2			0.31824		PASS			
Phase 3			0.31819		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3910	3.8	95.04 m	1.1	5	85.29	3.3	GO	95.6
Phase 2	3910		93.96 m			85.29		GO	
Phase 3	3910		94.27 m			88.24		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4395	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4396	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

