

DATE

18/08/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO GROUP AVEZZANO

PRODUCT

SCHORCH DA2408X BT714 Z
KW630 N°Comm 2020-0642

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00442	24.91	PASS	7.7	1.3	PASS
Phase 2			0.00443		PASS			
Phase 3			0.00448		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1014	3.8	603.6 u	0.7	5	49.02	1.9	GO	97.4
Phase 2	1014		603.6 u			48.08		GO	
Phase 3	1014		608.1 u			48.08		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	482	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

