

DATE

03/01/2025

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO AVEZZANO

PRODUCT

Rotore MENZEL MEBSSF560-04-
087 N°Comm 2024-0921

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00827	16.29	PASS	7.7	0.2	PASS
Phase 2			0.00825		PASS			
Phase 3			0.00825		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1178	3	1.350 m	0.2	7.5	57.5	2.5	GO	97.3
Phase 2	1157		1.352 m			57.5		GO	
Phase 3	1157		1.350 m			58.97		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1142	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1143	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	696	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

