

DATE

19/09/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCTELIN HKG 535L02F7B9 N Comm
2024 0706 N Rem 11775 (dopo lo**RESISTANCE TEST**

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	4.03155	17.93	PASS	7.7	0	PASS
Phase 2			4.03155		PASS			
Phase 3			4.03084		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	5928	3.8	334.2 m	1.3	5	79.37	2	GO	96.7
Phase 2	5928		335.5 m			78.13		GO	
Phase 3	5928		338.4 m			79.69		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1118	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1017	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

