

DATE

24/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

VEM KMER 315 MC-4 N COMM
2024_0445 N_REM 16587

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.04343	23.22	PASS	7.7	0.3	PASS
Phase 2			0.04329		PASS			
Phase 3			0.04334		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1264	3.8	1.310 m	0.2	5	45.65	2.2	GO	97.6
Phase 2	1264		1.310 m			45.65		GO	
Phase 3	1242		1.312 m			46.67		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

