

DATE

11/03/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI GUIDONIA

PRODUCT

ABB M3BP3154SMC N Comm 2024
0204 N Rem 16495

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01729	14.29	PASS	7.7	1.7	PASS
Phase 2			0.01729		PASS			
Phase 3			0.01759		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	5.2	1.085 m	0.9	6	45.45	0	GO	99.1
Phase 2	1328		1.075 m			45.45		GO	
Phase 3	1328		1.083 m			45.45		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1104	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

