

DATE

23/05/2024

PRODUCER

R.E.M. SRL

CUSTOMER

Buzzi Guidonia

PRODUCT

ANSALDO 400LW6 N COMM 2024
0427 N REM 16575 (prima del

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00699	20.82	PASS	7.7	0.7	PASS
Phase 2			0.00697		PASS			
Phase 3			0.00702		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1157	3.6	377.8 u	0.9	5	30.36	1.8	GO	97.3
Phase 2	1157		375.5 u			29.82		GO	
Phase 3	1157		374.3 u			29.82		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

