

DATE

19/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM SETTIMELLO

PRODUCT

MOTORE CGE TNA21 6 N COMM
2024 0510 N REM 16616 INDOTTO

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02275	28.15	PASS	7.7	1.4	PASS
Phase 2			0.02306		PASS			
Phase 3			0.02275		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	771	3.8	776.3 u	0.4	5	36.11	0	GO	99.6
Phase 2	771		779.6 u			36.11		GO	
Phase 3	771		778.0 u			36.11		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1005	0.039	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1004	23.42	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	728	407	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

