

DATE

19/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM SETTIMELLO

PRODUCT

MOTORE CGE TNA21 6 N COMM
2024 0510 N REM 16616

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.03477	27.35	PASS	7.7	0.5	PASS
Phase 2			0.03486		PASS			
Phase 3			0.03496		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	942	3.8	1.671 m	0.7	5	41.94	3.1	GO	96.2
Phase 2	942		1.659 m			40.63		GO	
Phase 3	942		1.667 m			40.63		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	953.1	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	940.2	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	535	278	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

