

DATE	PRODUCER	CUSTOMER	PRODUCT
05/07/2024	R.E.M. SRL	BUZZI SETTIMELLO	ROTORE CGE TNA21-6 N°Comm 2024-0510

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02305	27.66	PASS	7.7	0.4	PASS
Phase 2			0.02296		PASS			
Phase 3			0.02303		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	3.8	803.2 u	0.8	5	38.3	2.1	GO	97.1
Phase 2	1478		803.2 u			39.13		GO	
Phase 3	1478		810.0 u			38.3		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	915	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	642	342	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

