

DATE

20/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM

PRODUCT

STATORE CGE TNA21-6 N°Comm
2024-0510

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.03622	28.86	PASS	7.7	0.6	PASS
Phase 2			0.03645		PASS			
Phase 3			0.03641		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1171	3.8	1.890 m	0.8	5	44.07	0	GO	99.2
Phase 2	1171		1.906 m			44.07		GO	
Phase 3	1157		1.901 m			44.07		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	685	407	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

