

DATE

08/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

CEMENTERIA COSTANTINOPOLI

PRODUCT

STATORE HELMKE DSKK 710 06
N_11000046886 Comm 2024 0013

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.10793	12.6	PASS	7.7	1.3	PASS
Phase 2			0.10772		PASS			
Phase 3			0.10652		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3803	5.2	40.65 m	0.4	6	63.64	3	GO	96.6
Phase 2	3750		40.80 m			65.63		GO	
Phase 3	3803		40.72 m			65.63		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4851	0.009	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4866	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

