

DATE

14/03/2024

PRODUCER

R.E.M. SRL

CUSTOMER

RCR CRISTALLERIA

PRODUCT

LEROY SOMER LSPR 315 N_18461
Comm 2024 0107

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.04134	15.57	PASS	7.7	1.8	PASS
Phase 2			0.04164		PASS			
Phase 3			0.04088		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1414	5.2	1.190 m	1.4	6	41.3	3.2	GO	95.4
Phase 2	1414		1.190 m			41.3		GO	
Phase 3	1414		1.207 m			40		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

