

DATE

22/03/2024

PRODUCER

R.E.M. SRL

CUSTOMER

EOL SERVICE I

PRODUCT

GENERATORE SENZA TARGA
N°Comm 2024-0174 Avv 4Poli

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.08463	16.24	PASS	7.7	0.2	PASS
Phase 2			0.08473		PASS			
Phase 3			0.08483		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1257	2.5	2.582 m	0.4	5	50	2.8	GO	96.8
Phase 2	1300		2.573 m			51.43		GO	
Phase 3	1300		2.579 m			51.43		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1117	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

