

DATE

22/03/2024

PRODUCER

R.E.M. SRL

CUSTOMER

EOL SERVICE I

PRODUCT

GENERATORE SENZA TARGA
N°Comm 2024-0174 Avv 6 Poli

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.6168	16.37	PASS	7.7	0.2	PASS
Phase 2			0.61779		PASS			
Phase 3			0.6168		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1371	2.5	5.396 m	1	5	67.9	1.2	GO	97.8
Phase 2	1371		5.453 m			67.07		GO	
Phase 3	1371		5.409 m			67.9		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1066	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

