

DATE

02/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

EXCLUSIVE DESIGN

PRODUCT

VENETA ELETTROMECCANICA
MECRS 125 6L N_2303 10 Comm

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.25778	18.77	PASS	7.7	0.9	PASS
Phase 2			0.25852		PASS			
Phase 3			0.26009		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1414	3.8	4.544 m	1.1	5	58	1.5	GO	97.4
Phase 2	1414		4.544 m			58		GO	
Phase 3	1414		4.492 m			57.14		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST



	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	910	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)



DATE

02/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

EXCLUSIVE DESIGN

PRODUCT

VENETA ELETTROMECCANICA
MECRS 125 6L N_2303 10 Comm

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.25778	18.77	PASS	7.7	0.9	PASS
Phase 2			0.25852		PASS			
Phase 3			0.26009		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1414	3.8	4.544 m	1.1	5	58	1.5	GO	97.4
Phase 2	1414		4.544 m			58		GO	
Phase 3	1414		4.492 m			57.14		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	910	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

