

DATE

19/09/2024

PRODUCER

R.E.M. SRL

CUSTOMER

FIAT POMIGLIANO

PRODUCT

Statore ASGENH 315S4 N°Comm
2024-0710 N REM 16699

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01147	18.2	PASS	7.7	0.8	PASS
Phase 2			0.01138		PASS			
Phase 3			0.01138		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1228	3.8	335.8 u	0.7	5	26.32	0	GO	99.3
Phase 2	1214		336.9 u			26.32		GO	
Phase 3	1214		338.0 u			26.32		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1029	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1029	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

