

DATE	PRODUCER	CUSTOMER	PRODUCT
06/02/2024	R.E.M. SRL	FMA	ELETTROMANDRINO SENZA TARGA Comm 2024 0094

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.25987	16.02	PASS	7.7	1	PASS
Phase 2			0.25868		PASS			
Phase 3			0.25739		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1435	5.2	2.262 m	0.3	6	56.6	0	GO	99.7
Phase 2	1435		2.259 m			56.6		GO	
Phase 3	1435		2.257 m			56.6		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1144	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1143	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

