

DATE	PRODUCER	CUSTOMER	PRODUCT
29/07/2024	R.E.M. SRL	FMA	ELETTROMANDRINO SENZA TARGA Comm 2024-0568

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.24736	28.24	PASS	7.7	1.1	PASS
Phase 2			0.24475		PASS			
Phase 3			0.24694		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1500	3.8	2.104 m	2.4	5	54.55	0	GO	97.6
Phase 2	1500		2.156 m			54.55		GO	
Phase 3	1500		2.136 m			54.55		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	892	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

