

DATE

19/03/2024

PRODUCER

R.E.M. SRL

CUSTOMER

GEKO

PRODUCT

MOTORE VEM WE1R 280M 2 HB N
COMM 2024 0249 N REM 16510

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01637	17.26	PASS	7.7	0.2	PASS
Phase 2			0.01638		PASS			
Phase 3			0.0164		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	5.2	553.2 u	0.3	6	27.87	0	GO	99.7
Phase 2	1328		551.8 u			27.87		GO	
Phase 3	1314		551.8 u			27.87		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1131	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1000	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

