

DATE

03/04/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO ALLUMINIUM SLIM

PRODUCT

VENTILATORE REITZ MXE160 016
030 00 N COMM 2024 0295 N REM

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.09352	16.11	PASS	7.7	0.9	PASS
Phase 2			0.09361		PASS			
Phase 3			0.09281		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1200	3.6	3.066 m	3.5	5	56.52	0	GO	96.5
Phase 2	1178		3.086 m			56.52		GO	
Phase 3	1200		2.978 m			56.52		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

