

DATE

15/11/2024

PRODUCER

R.E.M. SRL

CUSTOMER

GFR ENGINEERING

PRODUCT

SIEMENS 1CV3252A
1LE15032CA234AB4 Z N°Comm

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.08995	13.75	PASS	7.7	0.9	PASS
Phase 2			0.08957		PASS			
Phase 3			0.08918		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	3.8	2.705 m	1.1	5	55.56	1.5	GO	97.4
Phase 2	1457		2.705 m			55.56		GO	
Phase 3	1435		2.736 m			54.72		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	892	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

