

DATE

10/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HENKEL

PRODUCT

SIEMENS 1LA6 206 2AA70 200L N
COMM 2024 0451 N REM 16592

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.23967	25.04	PASS	7.7	0.5	PASS
Phase 2			0.23848		PASS			
Phase 3			0.23963		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1542	3.8	4.236 m	1.2	5	60	0	GO	98.8
Phase 2	1542		4.186 m			60		GO	
Phase 3	1542		4.236 m			60		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1652	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1639	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1071	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

