

DATE

23/04/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO ALLUMINIUM SLIM

PRODUCT

VENTILATORE REITZ MXE160 016
030 00 N COMM 2024 0295 N REM

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.09251	16.11	PASS	7.7	0.5	PASS
Phase 2			0.09301		PASS			
Phase 3			0.09301		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	3.6	3.638 m	2.1	5	57.14	3	GO	94.9
Phase 2	1457		3.638 m			57.14		GO	
Phase 3	1435		3.563 m			58.93		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

